



Government Of West Bengal
Office Of The Divisional Fire Officer, Birbhum
West Bengal Fire & Emergency Services
Lalkhuti Para, Suri, Birbhum, Pin:- 731101

Memo no.: FSR/0125186231700227

Date: 01-11-2023

From:
Divisional Fire Officer, Birbhum
West Bengal Fire & Emergency Services

To: TAGORE MRINALINI DEVI TEACHER TRAINING COLLEGE
premises of:- Vill- Khanna, Po- Kanspai, Ps-Suri, Dist-Birbhum , Pin-731102 On Mouza-khanna, JL No-79, Plot No-36,42,43, Kh No-358 Under Koma Gram Panchayat

Sub: Fire Safety Certificate in favour of existing construction of G+2 storied building under group Educational occupancy, in favour of "TAGORE MRINALINI DEVI TEACHER TRAINING COLLEGE" Over Vill- Khanna, Po- Kanspai, Ps-Suri, Dist-Birbhum , Pin-731102 On Mouza-khanna, JL No-79, Plot No-36,42,43, Kh No-358 Under Koma Gram Panchayat.

This is in reference to your application no. 0125189231700076 dated 26-10-2023 regarding the Fire Safety Certificate in favour of existing construction of G+2 storied building under group Educational occupancy, in favour of "TAGORE MRINALINI DEVI TEACHER TRAINING COLLEGE" Over Vill- Khanna, Po- Kanspai, Ps-Suri, Dist-Birbhum , Pin-731102 On Mouza-khanna, JL No-79, Plot No-36,42,43, Kh No-358 Under Koma Gram Panchayat.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.
5. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
6. If required old line shall have to be replace with new lines, the cables shall always be laid in M.S conduit pipes

continuously bonded to the earth.

7.Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above-mentioned system.

8.Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

9.Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.

10.Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.

11.First aid firefighting system shall be provided as per I.S specification.

12.The notice of firefighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.

13.The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.

14.Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

15.Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

16.This Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid

Digitally Signed
Name: AMALES K. RAJ
Date: 01-Nov-2024 11:28
Reason: Approved
Location: West Bengal

Divisional Fire Officer Birbhum Divn, Birbhum
West Bengal Fire & Emergency Services